

01 June 2022



JOE MOROLONG
LOCAL MUNICIPALITY

Quotation Name : Procurement of 6 Skid Units
Quotation No : Q 4, 01/06/2022

Joe Morolong Local Municipality invites interested registered service providers to quote for the following:

Quotations Closing

Date: 09 June 2022

Time: 09:00

Venue: Joe Morolong Local Municipality Office

Street Address: Churchill Village, D320 Cardington Road

Returnable Documents Required:

- MBD Forms (1, 4, 8, & 9) for all Directors
- BBBEE Certificate or SWORN AFFIDAVIT – B-BBEE EXEMPTED MICRO ENTERPRISE
- Registered with the Joe Morolong Vendor Database
- Registered with Central Supplier Database (Quote CSD Number)
- Proof of rates & taxes for company from the relevant authority
- Proof of registration with South African Revenue Services (SARS)/ SARS Pin

Contact Person

Mrs M Melokwe: 053 773 9300/ 072 736 4322 & Mr T. Molaolwe: 053 773 9300 /082 829 9300


The quotation and supporting documentation must be enclosed in an envelope clearly endorsed with quotation name, number and must be submitted to Supply Chain Management Office, **not later than the prescribed time and date**. The quotation will be evaluated in accordance with the Joe Morolong Local Municipality's Supply Chain Management Policy, Preferential Procurement Policy Framework Act No 5 of 2000, using the 80/20 points system. The validity period of this quotation is 30 Days.

NOTE: Emailed or Faxed quotation will not be accepted. Please note that only vendors that are currently registered in the Joe Morolong Local Municipality Database and CSD can submit quotations for this advert.

Mr T. Tlhoale

Municipal Manager

Date: 01/06/2022



SPECIFICATION

1. Quantity of Skid Units = 6

(a) General description

The tank must have a nominal wall thickness of 10mm.

A low centre of gravity must be incorporated, which enhances the vehicles off road capability and will fit between the wheel arches on a pick-up load body.

A bump strip for protection and to be used for lifting must be incorporated into the surround of the tank.

(b) Tank


- 600lt, polyethylene, stepped tank design.
- Baffle to prevent water surge
- 450mm manhole with vented lid.
- 10mm nominal wall thickness.
- Fitted with equipment to prevent water surge.

(c) Pump and Engine

- 5 - 6 Hp Honda engine.
- High-pressure piston pump.
- A maximum pressurized flow must be ensured.

(d) Hose Reel, Hose and Nozzle





JOE MOROLONG
LOCAL MUNICIPALITY

- 1 x 30m Heavy duty hose reel, with Swivel.
- 30m x 10mm high-pressure hydraulic hose.
- 1 x G 20 adjustable high-pressure gun.
- Quick release couplings on all hose connections

(e) Venturi Refill System

Venturi Refill System with 5m x 40mm Kanaflex Hose.

(f) Receiving of high- pressure fire fighting unit

After the units has been received/ and delivered to the Municipality, the official responsible will test the units, on the date or day it is been received.

(g) Price

The price quoted for must include all the expenses the service provider will incur to have 6 (SIX) units delivered to Joe Morolong Local Municipality. Vat shall be indicated separately on the tender form.

